

SECTION 5 SALVAGE & OVERHAUL

Live Fire Training Prerequisite

- 5-I.01 Trainee shall identify the purpose of salvage, and its value to the public and the fire department.
NFPA 1001 4.3.14
- 5-I.02 Trainee, as an individual and as a member of a team, shall demonstrate folds and rolls of salvage covers.
NFPA 1001 4.3.14
- A. one-firefighter roll
 - B. one-firefighter double roll
 - C. one-firefighter fold
 - D. one-firefighter donut roll
 - E. one-firefighter accordion fold
 - F. two-firefighter accordion counter-payoff fold
 - G. two-firefighter fold
- 5-I.03 Trainee, as an individual and as a member of a team, shall demonstrate salvage cover throws.
NFPA 1001 4.3.14
- A. balloon throw
 - B. single-edge snap throw
 - C. double-edge snap throw
- 5-I.04 Trainee shall demonstrate the techniques of inspection, cleaning, and maintaining salvage equipment.
NFPA 1001 4.5.1
- A. Salvage covers
 - B. Hand tools
- 5-I.05 Trainee shall identify the purpose of overhaul.
NFPA 1001 4.3.13
- 5-I.06 Trainee shall demonstrate searching for hidden fires.
NFPA 1001 4.3.13
- 5-I.07 Trainee shall demonstrate exposure of hidden fires by opening ceilings, walls, floors, and pulling apart burned materials.
NFPA 1001 4.3.13
- 5-I.08 Trainee shall demonstrate how to separate and remove charred material from unburned material.
NFPA 1001 4.3.13
- 5-I.09 Trainee shall define and describe the following duties of firefighters left at the scene for fire and security surveillance, and identify the proper procedures for restoration of the premises after a fire.
NFPA 1001 4.3.14
- A. Making the building safe
 - B. Making the contents safe
 - C. Making the area safe
 - D. Restoring fire protection systems
 - E. Restoring utility services
 - F. Securing the building
 - G. Deodorizing the premises
 - H. Releasing the premises

- 5-I.10 Trainee, given salvage equipment, operating as an individual and as a member of a team, shall demonstrate the following skills:
NFPA 1001 4.3.14
- A. use of a water chute
 - B. construction of a water chute
 - C. use of a water catchall
 - D. construction of a water catchall
- 5-I.11 Trainee shall demonstrate the removal of debris, and removal and routing of water from a structure using the following techniques.
NFPA 1001 4.3.13, 4.3.14
- A. Water vacuums
 - B. Existing drains
 - C. Portable pumps
 - D. Brooms and squeegees
 - E. Buckets, mops, and shovels
- 5-I.12 Trainee shall demonstrate and describe the covering or closing of the following building openings made during fire fighting operations.
NFPA 1001 4.3.13
- A. Roofs
 - B. Doors
 - C. Windows
 - D. Floors
- 5-I.13 Trainee shall list the procedures to follow during overhaul.
NFPA 1001 4.3.13
- 5-I.14 Trainee shall identify precautions to be followed when overhauling targeted hazards.
NFPA 1001 4.3.13
- A. Trainee shall identify and describe the necessary precautions to maintain safety of firefighters and others during overhaul.
 - B. Trainee shall describe appropriate safety equipment and clothing for performing overhaul activities.
 - C. Trainee shall describe hazards associated with overhaul operations.
- 5-I.15 Trainee shall list four (4) indicators of fire in walls or ceilings.
NFPA 1001 4.3.13
- A. Sight
 - B. Touch
 - C. Sound
 - D. Electronic instruments
- 5-I.16 Trainee shall demonstrate restoration of the premises after a fire.
NFPA 1001 4.3.14
- A. Restoring fire protection systems
 - B. Restoring utility services
 - C. Deodorizing the premises
 - D. Releasing the premises

Firefighter I - There are no objectives required for this certification level.

Firefighter II - There are no objectives required for this certification level.