

SECTION 19 FIREFIGHTER PPE & SCBA

Live Fire Training Prerequisite

- 19-I.01 Trainee shall identify the various types of fire service protective clothing such as structural, wildland, and ARFF. Trainee shall also identify their components:
NFPA 1001 4.1.2, 4.3.9
- A. turnouts
 - B. helmets
 - C. gloves
 - D. boots
 - E. SCBA
- 19-I.02 Trainee shall identify procedures for inspecting, cleaning, and maintaining the components of a personal protective ensemble after each use.
NFPA 1001 4.1.2
- 19-I.03 Trainee shall describe the limitations of personnel working in a personal protective ensemble.
NFPA 1001 4.3.1.A
- 19-I.04 Trainee shall identify at least four (4) hazardous respiratory environments encountered in fire fighting.
NFPA 1001 4.3.1.A
- 19-I.05 Trainee shall demonstrate the use of SCBA in conditions of obscured visibility.
NFPA 1001 4.3.5, 4.3.5.A-B, 4.3.9
- 19-I.06 Trainee shall identify the physical requirements of the wearer, the limitations of the self-contained breathing apparatus, and the safety features of types of SCBA available to local AHJ.
NFPA 1001 4.3.1.A-B
- 19-I.07 Trainee shall demonstrate donning SCBA while wearing protective clothing:
NFPA 1001 4.3.2.A-B
- A. in a seated position on an apparatus with a seat belt on
 - B. Compartment Method
 - C. Overhead Method
 - D. Coat Method
- 19-I.08 Trainee shall demonstrate that the SCBA is in a safe condition for immediate use.
NFPA 1001 4.3.1
- 19-I.09 Trainee shall perform field reduction of contaminants.
NFPA 1001 4.5.1
- 19-I.10 Trainee shall demonstrate the use of SCBA in conditions of restricted passage.
NFPA 1001 4.3.1.A-B
- 19-I.11 Trainee shall demonstrate replacement of an expended cylinder on an SCBA assembly with a full cylinder.
NFPA 1001 4.3.1.B
- 19-I.12 Trainee shall identify the procedure for daily inspections and maintenance of SCBA.
NFPA 1001 4.3.9.A, 4.5.1, 4.5.1.A-B

- 19-I.13 Trainee, given each type of SCBA, shall demonstrate the correct procedure for recharging.
NFPA 1001 4.3.1.A-B
- 19-I.14 Trainee shall demonstrate the following emergency techniques using SCBA to:
NFPA 1001 4.3.5.B
- A. Emergency Preparedness
 - B. Control Breathing Techniques
 - C. Communications Procedures
- 19-I.15 Trainee shall identify and define the operational components of all types of self-contained breathing apparatus.
NFPA 1001 4.3.1, 4.3.1.A
- 19-I.16 Trainee, without compromising the rescuers respiratory protection, shall demonstrate rescue procedures for the following:
NFPA 1001 4.3.9.B
- A. a firefighter with functioning respiratory protection
 - B. a firefighter without functioning respiratory protection
 - C. a civilian without respiratory protection
- 19-I.17 Trainee shall demonstrate the operation of a Personal Alert Safety System (PASS) device.
NFPA 1001 4.3.1.B

Firefighter I - There are no objectives required for this certification level.

Firefighter II - There are no objectives required for this certification level.